

**Individual Groundwater Discharge Permit**  
**Fact Sheet**

**I. APPLICANT, FACILITY INFORMATION, and DISCHARGE LOCATION**

**Name and Address of Applicant:**

Mr. David Schreyack  
Pulte Homes of New England, LLC  
115 Flanders Road  
Westborough, MA 01581

**Name and Address of Facility where discharge occurs:**

Spyglass Landing Condominiums  
192 Grove St.  
Marshfield, MA 02050

**Discharge Information:**

Groundwater Discharge Permit Number: SE 1-754

The Groundwater Discharge Permit will allow the applicant to discharge 12,600 gallons per day of treated sanitary wastewater from **(eighty-four (84) over-55 condominium units - 168 bedrooms)** to groundwaters of the Commonwealth.

**II. LIMITATIONS AND CONDITIONS**

Discharge permit limitations are as listed in the ground water permit and are in conformance with 314 CMR 5.00, the Groundwater Discharge Permit Program.

**III. PERMIT BASIS AND EXPLANATION OF EFFLUENT LIMITATIONS**

An Individual Groundwater Discharge permit is required for this discharge in accordance with the Massachusetts Clean Water Act, M.G.L. c. 21, s. 26-53 and 314 CMR 5.03.

Effluent limitations are based upon the location of the discharge, the level of treatment, consideration of human health protection criteria and protection of the groundwaters of the Commonwealth.

The effluent discharge limits are in accordance with 314 CMR 5.10(4A)(e) and the criteria contained therein.

This information is available in alternate format. Call Donald M. Gomes, ADA Coordinator at 617-556-1057. TDD# 1-866-539-7622 or 1-617-574-6868.

MassDEP on the World Wide Web: <http://www.mass.gov/dep>



Printed on Recycled Paper

However, if pursuant to 314 CMR 5.10(4A)(e), the Department issues a permit that allows a discharge within a Zone II or Interim Wellhead Protection Area to meet effluent limitations less stringent than required by CMR 5.10(4A)(a),(c) and (d), the Department may modify the permit to provide that the discharge meet the applicable effluent limitations set forth in CMR 5.10(4A)(a),(c) and (d) if, at permit renewal, or any other time, the Department determines that such modification is necessary to protect the public health, safety, welfare, or the environment.

#### **IV. COMMENT PERIOD, HEARING REQUESTS, AND PROCEDURES FOR FINAL DECISIONS**

The public comment period for this permit is thirty (30) days following public notice in *The Environmental Monitor*. The public notice for this Individual Groundwater Discharge Permit occurred on [DATE].

Requests for an adjudicatory hearing must be submitted within thirty (30) days of the issuance/denial of the permit, by any person who is aggrieved by such issuance/denial.

A final decision on the issuance/denial of this permit will be made after the public notice period, and review of any comments received during this period.

#### **V. STATE CONTACT INFORMATION**

Additional information concerning the draft permit may be obtained between the hours of 9:00 a.m. and 5:00 p.m. Monday through Friday excluding holidays, from:

Jonathan E. Hobill  
20 Riverside Drive  
(508) 946-2870  
[Jonathan.hobill@state.ma.us](mailto:Jonathan.hobill@state.ma.us)

David Johnston, Regional DRD BWR  
Wastewater Management Program

6-23-2015

\_\_\_\_\_  
DATE